# **PRODUCT SUBMITTAL 173**


## RAUPEX SPEED O<sub>2</sub> barrier pipe



**Product:** RAUPEX® SPEED O<sub>2</sub> barrier pipe, SDR9

**Date:** 11 February 2021 (supersedes 08 March 2016)







Article No.	Nominal Size in	Average OD (A) in (mm)	Minimum Wall Thickness (B) in (mm)	Weight lb/ft (kg/m)	Capacity gal/ft (l/m)	Bend Radius in (mm)
160950	1/2	0.625 (15.88)	0.070 (1.78)	0.063 (0.093)	0.0098 (0.1222)	3.25 (82.5)

### **TECHNICAL DESCRIPTION**

Specification	English	SI	Standard	
Minimum Density	58 lb/ft³	926 kg/m³	ASTM F876	
Min. Degree of of Crosslinking	70%	70%	ASTM F876	
Max. Thermal Conductivity	2.84 Btu in./(ft <sup>2</sup> °F hr)	0.41 W/(m°K)	DIN 16892	
Coefficient of Linear Expansion	9.33X10-4 in/ft°F @ 68°F 1.33x10-3 in/ft°F @ 212°F	0.14 mm/(m°C) @ 20°C 0.2 mm/(m°C) @ 100°C	Mean @ 20- 70°C per DIN 16892	
IZOD Impact Res.	No Break	No Break		
Modulus of Elasticity	87,000-130,500 psi @ 68°F 43,500-58,000 psi @ 176°F	600-900 N/mm <sup>2</sup> @ 20°C 300-400 N/mm <sup>2</sup> @ 80°C	Minimum @ 20°C per DIN 16892	

TION					
Specification	English	SI	Standard		
Tensile Strength	4194-4355 psi @ 68°F 2610-2900 psi @ 176°F per ASTM D638	26-30 N/mm <sup>2</sup> @ 20°C 18-20 N/mm <sup>2</sup> @ 80°C per ASTM D638			
Roughness	e=0.00028 in	e=0.007 mm			
O <sub>2</sub> Permeability		<=0.32 mg/m²/day @ 40°C	DIN 4726		
Max. Short- term Exposure	150 psig @ 210°F (48 hr)	1035 kPa @ 99°C (48 hr)	ASTM F876		
UV Resistance	See TB218		ASTM F2657		

## **PRODUCT SUBMITTAL 173**

### RAUPEX SPEED O<sub>2</sub> barrier pipe



#### **FUNCTIONAL DESCRIPTION**

RAUPEX SPEED is an O<sub>2</sub> barrier pipe with a hook and loop wrap. RAUPEX O<sub>2</sub> barrier pipe is manufactured using REHAU's high-pressure peroxide method for crosslinked polyethylene (PEXa). RAUPEX pipe is according to ASTM F876, F877, NSF 61, CSA B137.5 and PPI TR-3. RAUPEX SPEED O<sup>2</sup> barrier pipe is manufactured by REHAU using a quality management system which has been certified to the latest version of ISO 9001. RAUPEX Speed O<sub>2</sub> barrier pipe is SDR9, red in color and for use with the EVERLOC+® compression-sleeve system certified to ASTM F877, the REHAU F1960 cold expansion fitting system certified to ASTM F1960, and RAUPEX compression nut fittings. See REHAU *Technical Bulletin TB261* for other compatible PEX fitting systems. RAUPEX SPEED O<sub>2</sub> barrier pipe has a co-extruded oxygen diffusion barrier that exceeds the strict requirements of DIN 4726.

RAUPEX SPEED  $O_2$  barrier pipe is ideal for use in radiant heating and cooling applications. RAUPEX SPEED  $O_2$  barrier pipe is not to be directly buried.

#### LONG-TERM STRENGTH

The maximum temperature and pressure ratings of the RAUPEX pipe are in accordance to ASTM F876, CSA B137.5 and PPI TR-3. The designer shall determine the actual conditions and apply the appropriate and additional design factors as required for any particular project. The temperature and pressure ratings apply to the application of RAUPEX pipe for conveying heating and cooling water at the 2.0 safety factor on allowable working pressure according to ASTM and CSA. According to the REHAU *PEXa Limited Warranty*, the RAUPEX pipe warranty period of 25 years is for operating conditions at or below 180°F (82.2°C) in permitted applications when the handling, use, installation and maintenance continually complies with all REHAU technical guidelines.

RAUPEX SDR9				
maximum pressures and temperatures	design factors			
160 psi @ 73.4°F (1055 kPa @ 23°C)	0.50	(per ASTM F876, CSA B137.5)		
100 psi @ 180°F (690 kPa @ 82.2°C)	0.50	(per ASTM F876, CSA B137.5)		
80 psi @ 200°F (550 kPa @ 93.3°C)*	0.50	(per ASTM F876, CSA B137.5)		

<sup>\*</sup> REHAU defines Elevated Temperature Applications as those with operating conditions greater than 180°F (82.2°C). When REHAU PEXa pipes are planned to be operated in Elevated Temperature Applications, contact REHAU Engineering to verify your project conditions comply with the REHAU *PEXa Limited Warranty* in accordance to REHAU *Technical Bulletin TB230 Elevated Temperature Applications*.

### **MATERIAL PLANNING**

For quick estimating purposes, the following guidelines may be of use for estimating the number of linear feet of pipe needed for your application. This material estimating information is not intended to be used for any particular project, nor as a final drawing requirement or specification, and is only provided as an aid for quick quotation purposes.

REHAU LoopCAD® radiant design software is recommended for calculating material lists for any particular project.

Pipe	Material Estimating		
Spacing	Factor Based on Pipe		
in.	Spacing		
5	2.4		
6	2.0		
7	1.7		
8	1.5		
9	1.4		
10	1.2		
11	1.1		
12	1.0		

Overpour Area ft²		Material Estimating Factor		Estimated Material Requirements (round up)	
	х		=	ft	

**Note**: Overpour Area x Material Estimating Factor as per Pipe Spacing (in) = Estimated Material Requirements

For updates to this publication, visit na.rehau.com/resourcecenter

The information contained herein is believed to be reliable, but no representations, guarantees or warranties of any kind are made as to its accuracy, suitability for particular applications or the results to be obtained therefrom. Before using, the user will determine suitability of the information for user's intended use and shall assume all risk and liability in connection therewith.