



Industrie Service

**REHAU AG + Co.
Ytterbium 4
91058 Erlangen**

The above organization is hereby entitled, on the basis of certificate No. 10 12 90277 001 and the appended test reports, to affix the certification body's certification mark shown below to the following product (see description below).



Requirement:

The product fulfils the requirements of PAS 1075 for all alternative installation techniques.

A restriction is that in the pipe bursting method for grey cast-iron pipes the maximum operating pressure must be limited to 5 bar in SDR 11 pipes and 3.2 bar in SDR 17 pipes.

The product also fulfils the stricter requirements outlined in MUC-KSP-A 3007.

Product description:

RAUPROTECT® made of PE 100-RC

One-layer solid wall pipes made of polyethylene 100-RC (resistant to cracks) with integrated coloured stripes (type 1 as per PAS 1075).

Applications and nominal sizes:

- Pipes made of polyethylene for alternative installation techniques as per PAS 1075 (Type 1)
- Nominal diameters: 63 mm to 355 mm, SDR 11 and SDR 17 (for gas, drinking water and sewage applications)
- Nominal diameters 25 mm to 50 mm, SDR 11 (for geothermal energy applications)

Manufacturing site:

REHAU AG + Co.
Von-Kleist-Straße
26919 Brake

This certificate is valid to December 2012

Third-party surveillance of production will be carried out on an annual basis

Munich 10 December 2010

TÜV SÜD Industrie Service GmbH
Institute for Plastics

i. A. Schweizer



TÜV SÜD Industrie Service GmbH is a testing, certification and inspection body approved by Deutsche Institute für Bautechnik (DIBt), Berlin