
TECHNICAL BULLETIN TB208

RAUPEX[®] PIPE AND CRIMP RING FITTINGS HYDRONIC HEATING SYSTEMS

Product: RAUPEX Pipe and Crimp Ring Fittings

Date: 01 January 2017 (supersedes 15 March 2013)

REHAU RAUPEX pipe is not recommended for use with the crimp ring fitting (CRF) system in hydronic heating systems. This applies to brass, copper (ASTM F1807), polymer (ASTM F2159) or any other type of crimp fittings. This includes connections to baseboard heaters, fan coil units and other hydronic applications, including radiant floor heating (RFH) systems. These limitations apply to both residential and commercial applications.

REHAU approves alternative fitting solutions for these applications: EVERLOC+[®] compression-sleeve fittings, ASTM F2080 compression-sleeve fittings and RAUPEX compression-nut fittings.

The REHAU *PEXa Limited Warranty* solely relating to RAUPEX pipe will remain valid as described in the limited warranty. The REHAU *PEXa Limited Warranty* does not apply to fittings or connections supplied by others.

For updates to this publication, visit na.rehau.com/resourcecenter

The information contained herein is believed to be reliable, but no representations, guarantees or warranties of any kind are made as to its accuracy, suitability for particular applications or the results to be obtained therefrom. Before using, the user will determine suitability of the information for user's intended use and shall assume all risk and liability in connection therewith.

© 2017 REHAU