
PRODUCT SUBMITTAL 1221

EVERLOC+® Polymer Run Reducing Tees



Product: EVERLOC+® Polymer Run Reducing Tees

Date: 07 February 2024 (supersedes 01 August 2017)



Article No.	Nominal Size	Α	B1	B2	C1	C2
	in	in (mm)	in (mm)	in (mm)	in (mm)	in (mm)
104841-001	3/4 x 1/2 x 3/4	3.11 (79.0)	1.02 (26.0)	0.73 (18.5)	0.56 (14.3)	0.41 (10.4)
104842-001	1 x 3/4 x 1	3.93 (99.7)	1.24 (31.5)	1.02 (26.0)	0.72 (18.3)	0.56 (14.3)
435709-001	1 1/2 x 1 x 1 1/2	5.16 (131.1)	1.88 (47.8)	1.3 (33)	1.03 (26.1)	0.72 (18.3)
435712-001	1 1/4 x 1 x 1 1/4	4.68 (118.8)	1.57 (40)	1.3 (33)	0.86 (21.9)	0.72 (18.3)
435716-001	1 1/2 x 3/4 x 1 1/2	5.25 (133.3)	1.88 (47.8)	1.02 (26.0)	1.03 (26.1)	0.56 (14.3)
435717-001	1 1/4 x 3/4 x 1 1/4	4.52 (114.9)	1.57 (40)	1.02 (26.0)	0.86 (21.9)	0.56 (14.3)
435809-001	1 x 1/2 x 1	3.57 (90.7)	1.3 (33)	0.73 (18.5)	0.72 (18.3)	0.41 (10.4)

TECHNICAL DESCRIPTION

Specification	ASTM F877 / CSA B137.5		
Material	Polyphenylsulfone (PPSU)		
Certifications	cNSFus-pw		

FUNCTIONAL DESCRIPTION

EVERLOC+ compression-sleeve fittings and sleeves are designed specifically for use with REHAU PEXa pipe. The maximum temperature and pressure ratings of the EVERLOC+ compression-sleeve fitting system is in accordance with ASTM F877 and CSA B137.5 for SDR9 PEX, see REHAU pipe product submittals for ratings. Installation is performed with EVERLOC+ compression-sleeve tools. Follow all published *REHAU Technical Guidelines*. All EVERLOC+ fittings and sleeves comply with the lead-free (LF) requirements of the U.S. Safe Drinking Water Act.