

TECHNICAL BULLETIN TB246 GEOTHERMAL MODELING WITH RAUGEO PEXa PIPES

Product: RAUGEO Ground Loop Heat Exchanger

Date: 16 Jan 12 (supersedes 23 Nov 09)

The RAUGEO system of ground loop heat exchangers has several distinct differences from conventional geothermal systems that must be considered when modeling with commercially available geothermal design programs. These differences include:

- Pipe dimensions
- Double U-bend configuration (optional)

Pipe Dimensions

Most conventional geothermal systems use HDPE pipe, which is produced in iron pipe sizes (IPS), with a standard dimensional ratio (SDR) of 11. RAUGEO PEXa pipes, on the other hand, are copper tube size (CTS), with an SDR of 9. Table 1 shows the dimensions of RAUGEO pipe.

Nominal pipe size (in)	Avg. OD (in)	Avg. wall thickness (in)	Avg. ID (in)
3/4	0.875	0.097	0.680
1	1.125	0.125	0.875
1 1/4	1.375	0.153	1.070
1 1/2	1.625	0.181	1.263
2	2.125	0.236	1.653

Table 1: RAUGEO Pipe Dimensions

When modeling with RAUGEO, ensure that the correct pipe size is specified in the software program. In most geothermal design software programs, the type of pipe is selected from a drop down menu. If the drop down menu does not show "PEXa," "RAUPEX" or "CTS SDR9" dimensions, the dimensions have to be typed in manually.

Note: The difference in thermal conductivity of HDPE and PEXa material is not included here. The variation in the thermal conductivity values produces a negligible effect in geothermal borehole modeling.

For updates to this publication, visit na.rehau.com/resourcecenter

The information contained herein is believed to be reliable, but no representations, guarantees or warranties of any kind are made as to its accuracy, suitability for particular applications or the results to be obtained therefrom. Before using, the user will determine suitability of the information for user's intended use and shall assume all risk and liability in connection therewith. © 2009 REHAU

Double U-bend Configuration

The double U-bend configuration refers to the number of U-bends, two, in a vertical borehole. This type of pipe configuration is found in most commercially available geothermal design programs, however the description varies. Name variations include:

- Two Vertical U-tubes
- Vertical 2 U-bends
- Double U-tube
- Vertical 2 U-tubes
- Vertical 2 pipe

The chosen type of U-bend configuration affects the calculated borehole thermal resistivity (BTR). For residential software programs, which often take a more simplistic calculation approach, the BTR is often not displayed. However, more advanced commercial programs not only display the BTR but allow the user to adjust the pipe spacing, grout type and borehole diameter. The BTR is calculated using a simple analytical equation specially developed for the selected U-bend configuration.

In 2011, REHAU teamed up with Bowman Geothermal of Chantilly, VA to create an in-depth numerical model to calculate the exact theoretical BTR of boreholes installed with RAUGEO PEXa double U-bends. The results are listed in Table 2. Because these values were derived directly from the basic principles of heat transfer, they are more accurate than the values calculated by geothermal design programs. If your program allows you to override the computed BTR by manual entry, REHAU recommends the use of these values instead.

	1 in. PEX		1 in. PEX		1 1/4 in. PEX	
	5 in. Borehole		6 in. Borehole		6 in. Borehole	
Grout TC	Spacers	No Spacers*	Spacers	No Spacers*	Spacers	No Spacers*
0.44	0.179	0.237	0.245	0.265	0.163	0.234
1.0	0.112	0.141	0.141	0.152	0.105	0.139
1.2	0.103	0.128	0.127	0.136	0.097	0.126

Table 2: Borehole Thermal Resistivity (in hr-ft °F/Btu) for various borehole combinations using the RAUGEO Double U-bend

* Average pipe spacing in the borehole assumed