

HOW TO SPECIFY RAUVISIO RADIANT HIGH GLOSS PANELS

Interior Finishes and Casework Section _____

Note: For additional information, contact:

REHAU Industries LLC

625 Kenmoor, Suite 105

Grand Rapids, MI 49546

Telephone: (888) 734-2810

(616) 285-6867

Fax: (616) 285-7622

Or <https://www.rehau.com/us-en/furniture>

PART I GENERAL

1.1 PRODUCT DELIVERY AND STORAGE

Deliver materials only when the project is ready for installation and the general contractor has provided a clean storage area.

Delivery of architectural millwork shall be made only when the area of operation is enclosed, all plaster and concrete work is dry and the area broom clean.

Maintain indoor temperature and humidity within the range recommended by the *North American Architectural Woodwork Standards* for the location of the project.

PART II PRODUCTS

2.1 RAUVISIO RADIANT PANELS

High gloss material shall be RAUVISIO radiant surface bonded to a suitable substrate as a laminated panel supplied by REHAU.

Color choice indicated by architect/designer.

2.2 BACKING SHEET

RAUVISIO radiant boards have a high gloss top sheet and a color matched melamine backer sheet. This ensures a properly balanced panel.

2.3 EDGEBANDING

Doors and drawer fronts must use color matching REHAU LaserEdge edgebanding in order to achieve a zero joint appearance. Edgeband must incorporate a polypropylene (PP) functional adhesive layer. A Laser, Hot Air, or Near Infra-red (NIR) edgebander machine is required.

PART III EXECUTION

3.1 INSPECTION

All decorative surfaces shall be inspected prior to further processing to ensure they are clean, and free of surface defects. Protective peel coat must remain intact until the finished components have been installed.

3.2 FABRICATION

RAUVISIO radiant boards when cut to size for the individual components (such as doors, drawer fronts, etc) shall be edgebanded with RAUVISIO laseredge edgebanding using a laser or hot air edgebander.

Cabinet construction type: FRAMELESS (preferred) or FACE FRAME.

3.3 INSTALLATION

RAUVISIO radiant finished components shall be installed conforming to industry standard practices, conditions, procedures and recommendations as specified by ANSI/NEMA LD-3-2005.